

# LICENCE

No. 21138 replaces No.19431

Issued to:

Applicant:

**Demes Kablo San Ve Tic LTD STI**  
**Istikal Mah. Maresal Fevzi Cakmak**  
**Caddesi No.19 Kirac, Esenyurt**  
**34500 ISTANBUL**  
**Turkey**

Licensee:

**Demes Kablo San Ve Tic LTD STI**  
**Istikal Mah. Maresal Fevzi Cakmak**  
**Caddesi No.19 Kirac, Esenyurt**  
**34500 ISTANBUL**  
**Turkey**



Product : cables for fixed wiring  
 Trade name(s) : DEMES KABLO  
 Type(s)/model(s) : XGB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1442

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 13/02/2019



ir. C. Lana,  
 Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



## SPECIFICATION OF THE CERTIFIED PRODUCT

### Product data

Product	:	cables for fixed wiring
Trade name(s)	:	DEMES KABLO
Type(s)/Model(s)	:	XGB
description	:	cable with copper conductor, unarmoured
insulating material	:	XLPE insulated and sheathed with G type halogen free compound
rated voltage Uo/U	:	0.6/1 kV
Fire propagation	:	minimum Cca-s1,d2,a1

### Additional information

2-core: 1.5 to 35 mm<sup>2</sup>  
 3-core: 1.5 to 35 mm<sup>2</sup>  
 4-core: 1.5 to 240 mm<sup>2</sup>  
 5-core: 1.5 to 35 mm<sup>2</sup>  
 7-core: 1.5 to 2.5 mm<sup>2</sup>

## TESTS

### Test requirements

NBN HD 604:2016 + Corrigendum 2017-01 + AC 2018-08

### Test results

The test results are laid down in certification file ref.630177/01

### Remarks


This certificate is based on test reports ref. 604114.01a, 604114.01b & 604114.01c

**Conclusion**

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 13/02/2019

Certification Manager :



*Luigi Zanutto* 2019-02-13

**FACTORY LOCATION(S)**

Demes Kablo San Ve Tic LTD STI  
Istikal Mah. Maresal Fevzi Cakmak  
Caddesi No.19 Kirac, Esenyurt  
34500 ISTANBUL  
Turkey