

LICENCE

No. 21141 replaces No.16541

Issued to:

Applicant:

Demes Kablo San Ve Tic LTD STI
Istikal Mah. Maresal Fevzi Cakmak
Caddesi No.19 Kirac, Esenyurt
34500 ISTANBUL
Turkey

Licensee:

Demes Kablo San Ve Tic LTD STI
Istikal Mah. Maresal Fevzi Cakmak
Caddesi No.19 Kirac, Esenyurt
34500 ISTANBUL
Turkey



Product : cables for fixed wiring

Trade name(s) : DEMES KABLO

Type(s)/model(s) : XVB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1442

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 18/02/2019

p.o. Etienne Thibaut

ir. C. Lana,
 Certification Manager



© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	cables for fixed wiring
Trade name(s)	:	DEMES KABLO
Type(s)/Model(s)	:	XVB
description	:	cable with copper conductors, unarmoured
insulating material	:	XLPE insulated and PVC sheathed
Fire propagation	:	minimum Cca,s3,d2,a3
rated voltage Uo/U	:	0,6/1 kV

Additional information

2-core: 1.5 to 35 mm²
3-core: 1.5 to 240 mm²
4-core: 1.5 to 240 mm²
5-core: 1.5 to 35 mm²
7-core: 1.5 to 2.5 mm²
9-core: 1.5 mm²
10-core: 1.5 mm²
12-core: 1.5 to 2.5 mm²

TESTS

Test requirements

NBN HD 604:2016 + Corrigendum 2017-01 + AC 2018-08

Test results

The test results are laid down in certification file ref.630178/01

Remarks


This certificate is based on test reports ref. 582031.02 a & 582031.02b

Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 18/02/2019

Certification Manager :

Ehene Thibaut

2019-02-18

FACTORY LOCATION(S)

Demes Kablo San Ve Tic LTD STI
Istikal Mah. Maresal Fevzi Cakmak
Caddesi No.19 Kirac, Esenyurt
34500 ISTANBUL
Turkey