

LICENCE

No. 23552 replaces No.16665

Issued to:

Applicant:

**Demis Kablo San Ve Tic LTD STI
Osmangazi Mah. Maresal Fevzi Cakmak
Caddesi No.19 Kirac, Esenyurt
34500 ISTANBUL
Türkiye**

Licensee:

**Demis Kablo San Ve Tic LTD STI
Osmangazi Mah. Maresal Fevzi Cakmak
Caddesi No.19 Kirac, Esenyurt
34500 ISTANBUL
Türkiye**



Product : cables for fixed wiring

Trade name(s) : DEMES KABLO

Type(s)/model(s) : EXVB

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1442

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 02/02/2026


ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



**005-PROD
ISO/IEC 17065:2012**



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	cables for fixed wiring
Trade name(s)	:	DEMES KABLO
Type(s)/Model(s)	:	EXVB
description	:	XLPE insulated cable-unarmoured
rated voltage U ₀ /U	:	0.6/1 kV
number of conductors	:	1 - 5
additional information	:	copper conductors
cross-sectional area(s)	:	See details here below

TESTS

Test requirements

NBN HD 603:2007 + A1:2016 + AC 10:2018 to A1:2016 + A2:2023

Test results

The test results are laid down in test reports ref. 586400.01a, 586400.01b and 635218.01

Remarks

Number of cores and cross sections:

- 1 copper core, 2.5 mm² to 500 mm² according to Table 3A
- 2 copper cores, 1.5 mm² to 35 mm² according to Table 3B
- 3 copper core, 1.5 mm² to 300 mm² according to Table 3C
- 4 Copper cores, 1.5 mm² to 300 mm² according to Table 3D
- 5 copper cores, 1.5 mm² to 35 mm² according to Table 3E
- 3 Copper cores + 1 of reduced section, 70/35 mm² to 300/150 mm² according to Table 3F

Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 02/02/2026

Certification Manager :



2026-02-02

FACTORY LOCATION(S)

Demes Kablo San Ve Tic LTD STI
Osmangazi Mah. Maresal Fevzi Cakmak
Caddesi No.19 Kirac, Esenyurt
34500 ISTANBUL
Türkiye